

عنوان مقاله:

Optimization Planning Model for Carbon Dioxide Emissions Reduction Via Renewable Energy Switch in a Coal Power Station

محل انتشار:

دوفصلنامه بهینه سازی در مهندسی صنایع، دوره 15، شماره 2 (سال: 1401)

تعداد صفحات اصل مقاله: 15

نویسندگان:

S. Siti Hafshar - *Instrumentation and Control Engineering Section, Malaysian Institute of Industrial Technology (MITEC), Universiti Kuala Lumpur, Johor Bahru, Johor, Malaysia*

A. Johari - *Centre of Hydrogen Energy (CHE), Faculty of Chemical and Energy Engineering, Universiti Teknologi Malaysia (UTM), Skudai, Johor, Malaysia*

H. Hashim - *Process Systems Engineering Centre (PROSPECT), Faculty of Chemical and Energy Engineering, Universiti Teknologi Malaysia (UTM), Skudai, Johor, Malaysia*

.Saeed Ahmed - *Department of Chemical Engineering, Abubakar Tafawa Balewa University (ATBU), Bauchi, Nigeria*

خلاصه مقاله:

Stable economy status has made many foreign investors invested in various industries sectors in Malaysia. Therefore, rapid development of industrial sector has caused the energy demand to increase tremendously year by year. To continue attract foreign investors, Malaysia has taken various efforts to maintain economic stability by developing a sustainable energy sector to ensure electricity demand is sufficient for industries with less cost, reliable supply, and also less impact to the environment. However, over dependence on fossil fuels as the main energy source could not guarantee the energy security and also could evoke issues of environmental problem mainly the increase in carbon dioxide (CO₂) emission in the atmosphere. In this study, a linear programming model and mixed integer linear programming optimization model under carbon constraints was developed to address issue of rising atmospheric concentrations of CO₂ from energy sector. The developed model was able to determine the optimum energy sources mix which is most economical and to satisfy the forecasted electricity demand at Tanjung Bin Power Station (TBPS) in Iskandar Malaysia region. The model includes energy source switching and analyzing different renewable energy technologies such as biomass system, biogas system, solar thermal and photovoltaic (PV) plant in power generation. The applicability of the model was tested on various CO₂ emission reduction targets which is at ۶, ۲۵, ۴۰ and ۵۰ % under several scenarios either without or with government subsidy. The results in this study indicated that the optimum energy source mix for TBPS is the mix of coal and solar energy (mainly solar thermal for without government subsidy and solar PV for with government subsidy). The results show that with government subsidy, the electricity tariff was acceptable for the consumers. The average electricity tariff at ۶, ۲۵, ۴۰ and ۵۰ % CO₂ emission reduction is RM ۰.۳۵, RM ۰.۴۴, RM ۰.۵۱ and RM ۰.۵۷ per kWh, respectively. Increase of CO₂ emission reduction show increase in electricity tariff compared to current tariff at RM ۰.۲۱ per kWh. Finally, by applying energy source switching, TBPS can significantly reduce CO₂ emission by avoiding ۱.۰۰ Mt of CO₂ emission at ۶ % of CO₂ emission reduction, ۴.۱۴ Mt of CO₂ emission at ۲۵ % of CO₂ emission reduction, ۶.۶۳ Mt of CO₂ emission at ۴۰ % of CO₂ emission reduction, and ۸.۲۸ Mt of CO₂ emission at ۵۰ % of CO₂ emission reduction by ۲۰۳۰.

<https://civilica.com/doc/1525432>

